



DECLARATION OF PERFORMANCE NO. FS-SP2004-01 EN

Unique identification code of the product-type	Art. Nr. 100930
Product name:	Fire Putty
Intended use:	Fire stopping and fire sealing
Manufacturer:	FireSeal AB Esbogatan 14 SE-164 74 Kista SWEDEN
System of AVCP:	SYSTEM 1
European Assessment Document:	EAD 350454-00-1104
European Technical Assessment:	ETA 20/0331
Technical Assessment Body:	UL Int. (UK) Ltd., anmält organ nr. 0843
EC Certificate:	0843-CPR-0537 (28.10.2019)

Declared performance:

Essential Characteristics	Declared Performance	Harmonised Technical Specification
Reaction to Fire	Class F	EN 13501-1
Resistance to Fire	EI 45/ 60/ EI 90/ EI 120	EN 13501-2 See ETA-20/0331 Annex A
Emissions	Category IA1	Declared by manufacturer & EN 16516
General aspects relating to fitness to use	Durability & Serviceability Y ₂	EAD 350454-00-1104, Clause 2.2.9
Other	NPD	-

NPD = No Performance Determined

An electronic copy of this declaration of performance and ETA 20/0331 is available for download at <https://fireseal.se/produkt-kategori/brandtatning/>



The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above:

For fire resistance, installation and configuration, see ETA 20/0331 daterad 18/05/2020

Signed for and on the behalf of the manufacturer by:

Kista Sweden, 2020-11-04

.....

Anders Wigant
Product Manager



The fireseal system originally developed to safeguard nuclear power plants

FireSeal AB
Esbogatan 14, 164 74 Kista
Box 7091, SE-16407 Kista, Sweden
+46(0) 8 623 61 60
www.fireseal.se